

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

| | |
|--|---|
| School District: | 50 - Haida Gwaii |
| School Name: | Sk'aadгаа Naay Elementary |
| REQUIREMENT: Regular inspection and maintenance of HVAC systems | Yes/No: Yes |
| | Date of last inspection: 2021-08-09 |
| | Date of next inspection: 2021-11-09 |
| | Date and type of most recent maintenance: Change of filters |
| RECOMMENDATION: Increase supply of outside air | Yes/No: Yes |
| | Detail: Increased to 30% from 10% |
| RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible | Yes/No: Yes |
| | Detail (Including filter grade): Increased all filters from MERV-9 to MERV-13 |
| RECOMMENDATION: Use other air cleaning or treatment technologies | Yes/No: No |
| | Detail: |
| RECOMMENDATION: Manage energy use and air distribution through building automation control systems | Yes/No: Yes |
| | Detail: All automated air systems are operating correctly |
| Other Relevant Information: | SD 50 presently meets all Ministry standards for ventilating systems. |
| District Contact for any Questions: | Name: Lao Peerless |
| | Phone Number: 250 559 8471 ext 107 |
| | Email: lpeerless@sd50.bc.ca |

