

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	50 - Haida Gwaii
School Name:	Tahayghen Elementary
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2021-08-24
	Date of next inspection: 2021-10-22
	Date and type of most recent maintenance: Change of filters
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes
	Detail: Increased to 30% from 10%
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Detail (Including filter grade): Increased all filters from MERV-9 to MERV-13
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: All automated air systems are operating correctly
Other Relevant Information:	
District Contact for any Questions:	Name: Lao Peerless
	Phone Number: 250 559 8471 ext 107
	Email: lpeerless@sd50.bc.ca

