

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	Haida Gwaii School District No. 50
<b>School Name:</b>	Daaxiigan Sk'adáa Née
	Yes/No:  Date of last inspection: August 29, 2024  Date of next inspection: November 29  Date and type of most recent maintenance: Filter change and visual inspection.
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes  Detail: There has been up to a 75% increase in the volume of outside air relative to the ASHRAE minimum. In cooler temperature the amount of outside air will decrease to maintain temperature set points.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No  Detail (Including filter grade): Currently using Merv 13. Filters will be spot checked regularly and changed a minimum of three times per year or as needed.
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No  Detail: Ventilation is currently controlled through the HVAC system.
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes  Detail: The building currently has an automated control system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Steve Goffic
	Phone Number: 250-559-8471
	Email: sgoffic@sd50.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	Haida Gwaii School District No. 50
<b>School Name:</b>	Port Clements Elementary
	Yes/No: Yes Date of last inspection: Jan 29, 2024 Date of next inspection: Oct 9, 2024 Date and type of most recent maintenance: Filter change and visual inspection.
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes Detail: There has been up to a 75% increase in the volume of outside air relative to the ASHRAE minimum. In cooler temperature the amount of outside air will decrease to maintain temperature set points.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No Detail (Including filter grade): Currently using Merv 13. Filters will be spot checked regularly and changed a minimum of three times per year or as needed.
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No Detail: Ventilation is currently controlled through the HVAC system.
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes Detail: The building currently has an automated control system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Steve Goffic Phone Number: 250-559-8471 Email: sgoffic@sd50.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	Haida Gwaii School District No. 50
<b>School Name:</b>	GidGalang Kuuyas Naay Secondary
	Yes/No: Yes Date of last inspection: Sept 23, 2024 Date of next inspection: Dec 23, 2024 Date and type of most recent maintenance: Filter change and visual inspection.
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes Detail: There has been up to a 75% increase in the volume of outside air relative to the ASHRAE minimum. In cooler temperature the amount of outside air will decrease to maintain temperature set points.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No Detail (Including filter grade): Currently using Merv 13. Filters will be spot checked regularly and changed a minimum of three times per year or as needed.
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No Detail: Ventilation is currently controlled through the HVAC system.
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes Detail: The building currently has an automated control system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Steve Goffic
	Phone Number: 250-559-8471
	Email: sgoffic@sd50.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	Haida Gwaii School District No. 50
<b>School Name:</b>	Sk'aadgaa Naay Elementary
	Yes/No: Yes Date of last inspection: Sept 27, 2024 Date of next inspection: Dec 27, 2024 Date and type of most recent maintenance: Filter change and visual inspection.
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes Detail: There has been up to a 75% increase in the volume of outside air relative to the ASHRAE minimum. In cooler temperature the amount of outside air will decrease to maintain temperature set points.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No Detail (Including filter grade): Currently using Merv 13. Filters will be spot checked regularly and changed a minimum of three times per year or as needed.
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No Detail: Ventilation is currently controlled through the HVAC system.
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes Detail: The building currently has an automated control system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Steve Goffic
	Phone Number: 250-559-8471
	Email: sgoffic@sd50.bc.ca

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

<b>School District:</b>	Haida Gwaii School District No. 50
<b>School Name:</b>	Agnes L. Mathers Elementary
	Yes/No: Yes Date of last inspection: Sept 20, 2024 Date of next inspection: Dec 20, 2024 Date and type of most recent maintenance: Filter change and visual inspection.
<b>RECOMMENDATION:</b> Increase supply of outside air	Yes/No: Yes Detail: There has been up to a 75% increase in the volume of outside air relative to the ASHRAE minimum. In cooler temperature the amount of outside air will decrease to maintain temperature set points.
<b>RECOMMENDATION:</b> Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No Detail (Including filter grade): Currently using Merv 13. Filters will be spot checked regularly and changed a minimum of three times per year or as needed.
<b>RECOMMENDATION:</b> Use other air cleaning or treatment technologies	Yes/No: No Detail: Ventilation is currently controlled through the HVAC in unit controller.
<b>RECOMMENDATION:</b> Manage energy use and air distribution through building automation control systems	Yes/No: Yes Detail: The building currently has an automated control system.
<b>Other Relevant Information:</b>	
<b>District Contact for any Questions:</b>	Name: Steve Goffic
	Phone Number: 250-559-8471
	Email: sgoffic@sd50.bc.ca