

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	Haida Gwaii School District No. 50
School Name:	GidGalang Kuuyas Naay Secondary
	Yes/No: Yes
	Date of last inspection: <i>Sept 16 12025</i>
	Date of next inspection: <i>Dec 12024 Sept 16 3 months</i>
	Date and type of most recent maintenance: <i>Sept 16 12025 changed filters</i>
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes Detail:
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No Detail (Including filter grade): Currently using Merv 13. Filters will be spot checked regularly and changed a minimum of three times per year or as needed.
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: No Detail: Ventilation is currently controlled through the HVAC system.
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: Yes Detail: The building currently has an automated control system.
Other Relevant Information:	
District Contact for any Questions:	Name: <i>Shannon Wilson</i> Phone Number: <i>250-637-1705</i> Email: <i>swilson@sd50.bc.ca</i>

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	Haida Gwaii School District No. 50
School Name:	Sk'aadgaa Naay Elementary
	Yes/No: Yes
	Date of last inspection: <i>Sept 19/2025</i>
	Date of next inspection: <i>3 months</i>
	Date and type of most recent maintenance: <i>Sept 19/2025</i> Filter change and visual inspection. <i>Priority Vac, cleaned ducting Sept 20, 21/2025</i>
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes
	Detail:
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No
	Detail (Including filter grade): Currently using Merv 13. Filters will be spot checked regularly and changed a minimum of three times per year or as needed.
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: No
	Detail: Ventilation is currently controlled through the HVAC system.
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: The building currently has an automated control system.
Other Relevant Information:	
District Contact for any Questions:	Name: <i>Shannon Wilson</i> Phone Number: <i>250-637-1705</i> Email: <i>swilson@sd50.bc.ca</i>

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	Haida Gwaii School District No. 50
School Name:	Agnes L. Mathers Elementary
	Yes/No: Yes <i>3e</i>
	Date of last inspection: <i>Sept 9/2025</i>
	Date of next inspection: <i>3 months</i>
	Date and type of most recent maintenance: Filter change and visual inspection. <i>Sept 9/2025</i>
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes Detail:
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No Detail (Including filter grade): Currently using Merv 13. Filters will be spot checked regularly and changed a minimum of three times per year or as needed.
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: No Detail: Ventilation is currently controlled through the HVAC in unit controller.
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: Yes Detail: The building currently has an automated control system.
Other Relevant Information:	
District Contact for any Questions:	Name: <i>Shannon Wilson</i> Phone Number: <i>250-637-1765</i> Email: <i>s.wilson@sd50.bc.ca</i>